



NOTES:

1. ALL PIPE AND FITTINGS SHALL BE THREADED BRASS.
2. DIELECTRIC FITTINGS SHALL BE USED AT THE CONNECTION OF ANY BRASS PIPE, VALVE OR FITTING TO THE CAST IRON AIR RELEASE VALVE.
3. SECURE STAINLESS STEEL SUPPORT BASE PLATES TO FLOOR WITH 1/4" STAINLESS STEEL EPOXY ANCHORS.
4. ADDITIONAL PIPE SUPPORTS MAY BE REQUIRED FOR PIPES LARGER THAN 2".
5. ALL CONCRETE SURFACES TO HAVE MANHOLE INTERIOR COATING.



Snyderville Basin Water
Reclamation District

DEAD END LOW PRESSURE
COMBINATION AIR VALVE

STANDARD DETAIL
LP-03A

Revision Date: 5/17/10