



NOTES:

1. ALL HDPE JOINTS SHALL BE BUTT FUSED. ALL PVC PIPE AND FITTINGS SHALL BE SCH. 80 PVC WITH THREADED JOINTS
2. SECURE STAINLESS STEEL SUPPORT BASE PLATE TO FLOOR WITH 1/4" STAINLESS STEEL EPOXY ANCHORS.



**Snyderville Basin Water
Reclamation District**

DUAL DEAD END LOW-PRESSURE FLUSHING CONNECTION

STANDARD DETAIL

LP-02A

Revision Date: 4/20/20