



NOTES:

1. ALL PIPE AND FITTINGS SHALL BE BUTT-FUSED HDPE.
2. SECURE STAINLESS STEEL SUPPORT BASE PLATES TO FLOOR WITH 1/4" STAINLESS STEEL EPOXY ANCHORS.
3. REFERENCE DETAIL LP-01B FOR ADDITIONAL DETAILS.



**Snyder Basin Water
Reclamation District**

**LOW PRESSURE
JUNCTION MANHOLE**

**STANDARD DETAIL
LP-01A**

Revision Date: 2/22/16