



NOTE:

1. A SAMPLING MANHOLE IS NOT REQUIRED DOWNSTREAM OF A GREASE INTERCEPTOR SERVING A COVERED PARKING STRUCTURE



**Snyderville Basin Water
Reclamation District**

**SAMPLING MANHOLE
PRECAST BASE**

STANDARD DETAIL

PT-02

Revision Date: 4/20/20